

Annexure-III

Site Inspection Report for construction of CT/PT

ULB Name	Date: 15/1/25	
Ward No	Dainhat Municipality	
Name of the proposed site	13	
Address	Battala kazi para Masjid	
Category CT/PT	Battala kazi para Masjid, Ward NO-13	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	CT
	Dag No., Khatian No., J.L. No. & other plot information.	Masjid
	No objection Certificate received from the concerned authority (Yes/No)	JL NO-87, Plot NO-73 Khatian NO-848, Mouza-Baghtikra
Nearest location of CT/PT (approx distance in meter)		
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	Model - F
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well	yes.	
Availability of surface water/piped water supply (in details)	available	
Operation and Maintenance plan in detail	3rd party	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	
	Contact No	9339875575
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	SAYAN MUKHERJEE S.A.E
	Contact No	6294558601
	Signature with Seal	

15/1/25
Sub-Assistant Engineer
Dainhat Municipality