



Annexure-III		
Site Inspection Report for construction of CT/PT		
		Date : 11.12.2024
ULB Name	Bishnupur Municipality	
Ward No		16
Name of the proposed site	Netaji Nagar Colony, near Durga Mandir	
Address	Netaji Nagar Colony, near Durga Mandir	
Category CT/PT/ Institution	CT	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	Netaji Nagar Soloana Committee
	Dag No., Khatian No., J.L. No. & other plot information.	Mouza: Turki Sitarampur J.L. No.- 100 RS no: 276/595
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	No	
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only applicable for PTs)	Aspirational/Normal	Aspirational/Normal
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	Model : 6T
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Piped Water	
Operation and Maintenance plan in detail	Community Users	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Prabir Mukherjee ( Civil Engineer)
	Contact No	9339875575
	Signature with Seal	 Checked & Verified Engineer (Civil) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	Somanath Roy (SAE)
	Contact No	8250938005
	Signature with Seal	 S.A.E. Bishnupur Municipality

S.A.E.  
Bishnupur Municipality