

Annexure-III

SL-5

Site Inspection Report for construction of CT/PT

Date : 13.12.2024

ULB Name	SAINTHIA	
Vard No	3	
Name of the proposed site	RUPALI MORE	
Address	SAINTHIA	
Category T/PT	CT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	PLOT NO-724,MOUZA-SAINTHIA,JL-95
	No objection Certificate received from the concerned authority	NA
Nearest location of CT/PT (approx distance in meter)	NA	
Proposed no of Toilet seats	Male	
	Female	
Proposed no of Urinal seats	Male	
	Female	
To be constructed as Aspirational Toilet or Normal Toilet (only applicable for	Aspirational/Normal	
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Place identified for installation of Soakpit and Soak Well		
Availability of surface water/piped water supply (in details)		
Operation and Maintenance plan in detail		
Remarks if any:	INSUFFICIENT LAND ,NOT SUITABLE FOR CONSTRUCTION	
Representative assigned from Hiji Inspiration for the site inspection	Name & Designation	ABHIK MAJUMDAR(ENGINEER) <i>ABHIR MUKHOPADHYAY</i>
	Contact No	9339875575 / 9851301709
	Signature with Seal	<i>Abhir Mukhopadhyay</i> Checked & Verified Engineer (Civil) Hiji INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	DEBARPAN DATTA
	Contact No	8250639494
	Signature with Seal	Debarpan Datta <i>Debarpan Datta</i>