





## Annexure-III

## Site Inspection Report for construction of CT/PT

Name	Date : 18.09.2024	
Ward No	Jangipur Municipality	
Name of the proposed site	2	
Address	Costruction of Community Toilet near Patchmatha Primary School at Joyrampur, Plot No- 328, Khatian No- 1887, JL No- 018, Mouza - Joyrampur In Ward No- 02 within Jangipur Municipality.	
Category CT/PT	Ward No - 02, Jangipur Municipality	
Necessary Land Details	Wheater the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Plot No- 328, Khatian No- 1887, JL No- 018, Mouza - Joyrampur
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	Approx 1.00 KM available CT	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.50 Sq Meter ( 5.00 Mtr X 4.5 Mtr)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1200X1000
	Urinal (Minimum=500x600)	600X500
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Yes	
Operation and Maintenance plan in detail	USER GRUP	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Shahid Anwar Ansari Junior Engineer
	Contact No	7980028462
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Abdur Rashid Sk, Sub - Assistant Engineer
	Contact No	9800658686
Checked & Verified Signature with Seal		 Sub-Asstt. Engineer Jangipur Municipality
 Engineer (Civil) HIJLI INSPIRATION		 Chairman Jangipur Municipality