

Annexure-III

Site Inspection Report for construction of CT/PT

Date :

①

Name	Garulia	
Ward No	05	
Name of the proposed site	Maharaja Pratap park	
Address		
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	
	No objection Certificate received from the concerned authority	yes.
Nearest location of CT/PT (approx distance in meter)		
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal (B)
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1500 X 1200
	Urinal (Minimum=500x600)	500 X 600
Space identified for installation of Soakpit and Soak Well	yes.	
Availability of surface water/piped water supply (in details)	yes	
Operation and Maintenance plan in detail	Agency	
Remarks if any:		
Representative assigned from Hiji Inspiration for the site inspection	Name & Designation	Prabir Mukherjee (Engineer)
	Contact No	9339875575
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Susanta Sarkar (S.A.E.)
	Contact No	9804188879
	Signature with Seal	

Checked & Verified
 Engineer (Civil)
 Hiji INSPIRATION

Sub-Assistant Engineer
 Garulia Municipality