



Site Inspection Report for construction of CT/PT

Date: 23.12.24

ULB Name	Taherpur NAA	
Ward No	12	
Name of the proposed site	Construction of Public Toilet (PT) at UHWA 115-3	
Address	Taherpur B/28	
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Dag No R.S 5450, Khatian No 577, Mouza Mahisdanga, Plot No 04, Ward No-13, Taherpur
	No objection Certificate received from the concerned authority (Yes/No)	
Nearest location of CT/PT (approx distance in meter)	NO	
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only applicable)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	Model - G
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Pipe water	
Operation and Maintenance plan in detail	ULB	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Checked & Verified
	Contact No	9339175521
	Signature with Seal	 Engineer (SWM) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	 Nodal Engineer, SWM
	Contact No	Taherpur Notified Area Authority
	Signature with Seal	Taherpur, Nadia

S.I-24