





Annexure-III

Site Inspection Report for construction of CT/PT

		Date : 18.09.2024
ULB Name	Jangipur Municipality	
Ward No	6	
Name of the proposed site	Construction of Public Toilet near house of Khalek Sk at Boroj, Plot No- 1365, Khatian No- 1693, JL No- 007, Mouza Jangipore in Ward No- 06 within Jangipur Municipality.	
Address	Ward No - 06, Jangipur Municipality	
Category CT/PT	PT	
Necessary Land details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Plot No- 1365, Khatian No- 1693, JL No- 007, Mouza- Jangipore
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	Approx 1.00 KM available PT	
Proposed no of Toilet seats	Male	4
	Female	3
Proposed no of Urinal seats	Male	4
	Female	3
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	49.97 Sq Meter (8.225 Mtr X 6.075 Mtr)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1500X1000
	Urinal (Minimum=500x600)	1200X1000
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Yes	
Operation and Maintenance plan in detail	HIGH BOROJ MOSQUE COMMITTEE	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Shahid Anwar Ansari Junior Engineer
	Contact No	7980028462
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Abdur Rashid Sk, Sub - Assistant Engineer
	Contact No	9800658686
	Signature with Seal	

Checked & Verified

 Engineer (Civil)
 HIJLI INSPIRATION


 Sub-Assit. Engineer
 Jangipur Municipality


 Chairman
 Jangipur Municipality