

## Annexure-III

## Site Inspection Report for construction of CT/PT

Name	Date : 19.09.2024	
Ward No	Jangipur Municipality	
	11	
Name of the proposed	Construction of Community Toilet near house of Kabir SK at Islampur, Plot No- 1072, Khatian No - 3659, JL No- 019, Mouza - Chhotkalia in Ward No- 11 Within Jangipur Municipality.	
Address	Ward No - 11, Jangipur Municipality	
Category CT/PT	CT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ASIKUL SK, S/O - SUKURUDDIN SK
	Dag No., Khatian No., J.L. No. & other plot information.	Plot No- 1072, Khatian No - 3659, JL No- 019, Mouza - Chhotkalia
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	Approx 1.00 KM available CT	
Proposed no of Toilet Seats	Male	4
	Female	3
Proposed no of Urinal Seats	Male	4
	Female	3
Can be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	49.97 Sq Meter ( 8.225 Mtr X 6.075 Mtr)
Area requirement Details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1500X1000
	Urinal (Minimum=500x600)	1200X1000
Is a place identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Yes	
Operation and Maintenance plan in detail	USER GRUP	
Remarks if any:		
Representative Signed from Hijli Inspection for the site Inspection	Name & Designation	Shahid Anwar Ansari Junior Engineer
	Contact No	7980028462
	Signature with Seal	
Representative Signed from the ULB for the site inspection	Name & Designation	Abdur Rashid Sk, Sub - Assistant Engineer
	Contact No	9800658686
	Signature with Seal	



SUB-ASST. Engineer  
Jangipur Municipality

Chairman  
Jangipur Municipality

Engineer (Civil)  
Hijli INSPIRATION