

Site Inspection Report for construction of CT/PT		
		Date : 16.01.25
ULB Name	KHARAGPUR MUNICIPALITY	
Ward No	32	
Name of the proposed site	Shanti chawk mata mandir	
Address	chota ayma	
Category CT/PT	CT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Rail
	Dag No., Khatian No., J.L. No. & other plot information.	
	No objection Certificate received from the concerned authority (Yes/No)	Yes NO
	Site Plan	
Nearest location of CT/PT (approx distance in meter)	200 mtr	
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	2
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only applicable for PTs)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	
Area requirement Details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	CT- Plan-3
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak well	Yes	
Availability of surface water/Piped water supply (in details)	Pipe water	
Operation and Maintenance plan in detail	community.	
Remarks if any:	H-H-45	
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Checked & Verified
	Contact No	9339825575
	Signature with Seal	Prabin Kumar Saha Engineer (Civil)
Representative assigned from the ULB for the site inspection	Name & Designation	Vivekananda Hijli INSPIRATION
	Contact No	8927462868
	Signature with Seal	Vivek Sub-Assistant-Engineer Kharagpur Municipality

S.L-58