



Site Inspection Report for construction of CT/PT

Date: 15.01.25

ULB Name	KHARAGPUR MUNICIPALITY	
Ward No	13 -	
Name of the proposed site	Nimpura Veg Market.	
Address		
Category CT/PT	PT.	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Rail.
	Dag No., Khatian No., J.L. No. & other plot information.	
	No objection Certificate received from the concerned authority (Yes/No)	Yes.
	Site Plan	
Nearest location of CT/PT (approx distance in meter)		
Proposed no of Toilet seats	Male	2
	Female	3
Proposed no of Urinal seats	Male	2
	Female	3
To be constructed as Aspirational Toilet or Normal Toilet (only applicable for PTs)	Aspirational/Normal	Normal (A).
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	57.75 sqm.
Area requirement Details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1200 x 1000
	Urinal (Minimum=500x600)	600 x 500
Space identified for installation of Soakpit and Soak well		Yes.
Availability of surface water/Piped water supply (in details)		Yes.
Operation and Maintenance plan in detail		Agency.
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	SHAHID ANWAR ANSARI, Eng.
	Contact No	7980028462
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Subrata Mandal (SAE)
	Contact No	9434414354
	Signature with Seal	

S.L-9

Sub-Assistant-Engineer
Kharagpur Municipality