



Annexure-III

Site Inspection Report for construction of CT/PT

Date :24/10/2024

KONNAGAR MUNICIPALITY		
14		
Sec. Konnagar Municipality Mitra Ghat		
N-416,I.G ROAD		
PT		
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Dag No.-6033&6031, Khatian No.-1852, J.L. No.-7 & Area.-11Katha 04Chatak
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)		800 mtr
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Aspirational
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	5 m X 4.5m
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1200 x 1000
	Urinal (Minimum=500x600)	500x600
Space identified for installation of Soakpit and Soak Well		Yes
Availability of surface water/piped water supply (in details)		Yes
Operation and Maintenance plan in detail		Maintenance by ULB
Remarks if any:		Cancel- Minimum required land is not available
Representative assigned from Pujli Inopation for the site inspection	Name & Designation	
	Contact No	
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	KOUSHIK MONDAL (S.A.E)
	Contact No	7688079640
	Signature with Seal	



Chandrabati
Executive Officer
Konnagar Municipality

Chandrabati
Executive Officer
Konnagar Municipality

Chandrabati
Chairman
Konnagar Municipality