



Annexure-III

Site Inspection Report for construction of CT/PT

Date : 29.08.2024

ULB Name	MIDNAPORE Municipality	
Ward No	9	
Name of the proposed site	Dharma,Kamarpara,Ward no-9,	
Address	Ward no-9,Kamarpara,Dharma,Midnapur,721101	
Category CT/PT	PT	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Mouza_Kamarpara J.L NO-187,R.S Plot No-630 P
	No objection Certificate received from the concerned authority	Yes
Nearest location of CT/PT (approx distance in meter)	NA	
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	35.7 Sqm (Model- G)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well	YES	
Availability of surface water/piped water supply (in details)	YES	
Operation and Maintenance plan in detail	ULB will maintain	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Abhik Majumdar (Engr.)
	Contact No	9851301709
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Engineer (Civil) Soumen Das (SAE) Hijli INSPIRATION
	Contact No	7384887839



**MODEL DRAWING FOR CONSTRUCTION OF C. T./P.T.
TOILET SEATS 4 Nos URINAL 5 Nos
MODEL NO. - G**

